

OSNA make Shunt Zener Diode Safety Barriers are passive network of components, limits the excessive flow of electrical energy from safe area to the hazardous area.


All OSNA make Zener Barriers are designed, manufactured under strict quality control according to the Harmonised European Standard EN 60079-0:2012+A11:2013, EN 60079-11:2012 and are approved by BUREAU VERITAS. CMRS for Ex ia, II C

New approved by Certificate No. EPS 15 ATEX 1 128 X



TYPE NO.	DESCRIPTION	TYPE	FUSE RATING (mA)	OUTPUT PARAMETERS		I_{SC} AMPS	OPTIMUM POWER Watts	FACTOR OF SAFETY IIC
				U_Z volts	R_{min} ohms			
Z366/Ex	12.8V 156 ohm 12.8V 156 ohm	A.C.	50	a1 12.8	156	0.082	0.26	21
				b1 12.8	78	0.163	0.52	10
				b2 25.6	312	0.082	0.52	2.19

Connection Diagram



Housing Dimensions

